

Field Inspection Report: SPDES GP-0-20-001

Project Name: Pilot Travel Center CTM Proj. #: 21.1029

SPDES Permit: NYR11I522

Date: Nov. 19, 2021 Time: 8:00 AM Inspector/ Title Ryan Myers, I.E.

Weather During Inspection 35° Overcast

Previous 24 hours: Overcast with showers.

Site Soil Conditions: Soils are saturated from rain previous day.

Description of Run off at Discharge Points No discharge observed.

Erosion and Sediment Control Features:		(Refer to Map for Location)
	Condition	Corrective Action Required
Silt Fence	Good	
Road Sweeping / Offsite	Good	
Construction Entrances	Good	
Riprap Outlet Protection	N/A	
Temporary Sediment Trap(s)	Good	
Erosion Control Blanket	N/A	
Check Dam(s)	N/A	
Concrete Washout	Good	
Other: Silt Socks	Good	
Ramp	N/A	
Inlet Protection	Good	
Description of Disturbed Area:	Contractor working on excavating and grading site for utilities and stormwater practices. Soils are slightly saturated. Silt fence in place around perimeter of disturbed areas. Total disturbed area measured to be +/- 4.2 acres.	
Description of Stabilized Areas:	Contractor working on grading subbase for paved/concrete areas and paving asphalt areas. Contractor working on setting steel for the building and pouring concrete slabs. Stabilized area of stone, asphalt, and concrete measured to be +/- 7.4 acres.	


Field Inspection Report: SPDES GP-0-20-001

Areas that Require Stabilization:	None
Permanent Stormwater Management Practices:	Stormwater ponds excavated and graded with outlet structures installed.

Practices not in conformance with SWPPP: None.

Repairs Required: None

Improvements Since Last Visit: Low structures have been raised and asphalt is being placed for paved areas.

Signature of Qualified Inspector: 

Date Inspection Mailed to Owner/Contractor: 11/19/2021

Signature of Owner (if required):
