



30 Century Hill Dr. Suite 301
Latham, NY 12110
888-898-6273
888-843-6778 Fax

T R A N S M I T T A L

DATE: March 30, 2022
TO: Town of Glen Planning Board
7 Erie Street
Fultonville, NY 12072
(518) 848-4498
CC: Douglas Cole, P.E.
FROM: Gregory Gibbons, P.E.

T R A N S M I T T E D V I A :

- Fax No.:
 - U.S. Mail
 - Courier Rush Regular
 - Overnight
 - Hand Deliver
 - Pick Up
 - Other:
- Total number of sets included: 5

Qty.	Description	Date
5	2621 Rte 5s Revised Plan Set (24x36)	02/18/2022

Hello,

We are submitting the above plans for Planning Board review. The changes from the previously approved plans are as follows:

- Replaced the proposed culvert beneath the road with a cattle guard crossing to limit grading impacts and to provide a hydraulic connection between the USACE regulated wetland. This has been permitted by USACE. W
- Added gravel diaphragms along contours throughout the solar panel area per NYSDEC Stormwater General Permit guidance. This has been requested on all recent projects by NYSDEC
- Reduced the number of solar panels and decreased the system fenced area from 19.41 acres to 18.83 acres.

Thank you,

Gregory E. Gibbons, P.E.
Civil Engineer
Borrego Solar Systems, Inc.
315-378-9567
ggibbons@borregosolar.com